


NOTES
 COIL ABOVE 1270mm FH
 SUPPLIED IN TWO SECTIONS

☐ COIL LABEL ON ALL COILS ORDERED.
 MARKED WITH JOB NUMBER AND COIL CODE.
 MULTIPLE COILS TO BE COMMONLY MARKED
 WITH ALL REFERENCES.

Deep	DEPTH	FIN WIDTH
3	133.5	82.2
4	161	109.6
5	188.5	137
6	216	164.4
8	271	219.2

WATER FLOW (L/S)	Header Size (Ø)	Conn. Size (Ø)
0.29	28	22
0.4	28	22
0.8	28	22
1.39	35	28
2.8	42	35
4.8	54	42
7.3	67	54
10.3	80	67
20.0	107	80



<small>COPYRIGHT © This document and the copyright in the design and drawings are the property of Cooke Industries Limited. The content of this document may not be reproduced either in whole or in part by any means whatsoever without the prior written consent of Cooke Industries Limited.</small>			<small>SCALE</small> NTS
<small>DRAWN</small> SV	<small>APPROVD</small> AC	<small>FILE REF</small> CWC-01	<small>DATE</small> 20/12/99
<small>DATE</small> 20/12/99	<small>DATE</small> 20/12/99	<small>DRW NO.</small> -	<small>REV</small> -

TITLE
AIRPAK COILS
 Standard Cooling Coil

COOKE INDUSTRIES

P.O. Box 12021, Penrose, Auckland 1150
 31 Station Rd, Penrose, Auckland, N.Z.
 Phone: 011 739 2181
 Email: sales@cookeindustries.co.nz

PROJECT - **REV** -