


**NOTES**

COIL ABOVE 1270mm FH  
SUPPLIED IN TWO SECTIONS

☐ COIL LABEL ON ALL COILS ORDERED.  
MARKED WITH JOB NUMBER AND COIL CODE.  
MULTIPLE COILS TO BE COMMONLY MARKED  
WITH ALL REFERENCES.

Deep	DEPTH	FIN WIDTH
1	78.5	27.4
2	106	54.8
3	133.5	82.5

WATER FLOW (L/S)	Header Size (Ø)	Conn. Size (Ø)
0.29	28	22
0.4	28	22
0.8	28	22
1.39	35	28
2.8	42	35
4.8	54	42
7.3	67	54
10.3	80	67
20.0	107	80



<small>COPYRIGHT ©: This document and the copyright in this document remain the property of Cooke Industries Limited. The content of this document may not be reproduced either in whole or in part by any means whatsoever without the prior written consent of Cooke Industries Limited.</small>		
DRAWN: SW	APPRVD: AC	SCALE: NTS
DATE: 20/12/99	DATE: 20/12/99	FILE REF: HWC-01
	DRW NO: -	

<b>TITLE: AIRPAK COILS</b> Standard Heating Coil	
<b>COOKE INDUSTRIES</b>	P O Box 12021, Penrose, Auckland 1135 31 Station Rd, Penrose, Auckland, NZ PH (64 - 9) 579 2185 Fax (64 - 9) 579 2181 Email: sales@cookeindustries.co.nz
PROJECT: -	REV: -