

Fillcontrol Auto Compact

GB

<text>

Cooke Industries - Phone: +64 9 579 2185 Email: sales@cookeindustries.co.nz Web: www.cookeindustries.co.nz

1	Notes on the operating manual3					
2	Liabil	Liability and guarantee3				
3	Safet	ty3				
	3.1	Explanat	tion of symbols3			
		3.1.1	Symbols and notes used			
	3.2	Personn	el requirements			
	3.3	Persona	protective equipment3			
	3.4	Intendeo	1 use			
	3.5	Inadmis	sible operating conditions3			
	3.6	Residual	risks			
4	Descr	iption c	of the device4			
	4.1	Descript	ion4			
	4.2	Overviev	<i>N</i> 4			
	4.3	Identific	ation4			
		4.3.1	Nameplate4			
		4.3.2	Type code4			
4.4 Function		Functior	۱4			
	4.5	Scope of	delivery5			
	4.6	Optiona	l equipment and accessories5			
5	Techr	nnical data5				
6	Instal	lation	5			
	6.1	Installat	ion conditions6			
		6.1.1	Incoming inspection6			
	6.2	Preparat	ory work6			
	6.3	Executio	n6			
		6.3.1	Fitting the add-on components6			
		6.3.2	Wall mounting6			
		6.3.3	Hydraulic connection6			
	6.4	Switchin	g and make-up variants7			
	6.5	Electrica	l connection7			
		6.5.1	Terminal diagram8			
		6.5.2	RS-485 interface8			
	6.6 Installation and commissioning certificate					

7	Comr	nissioni	ng	8				
	7.1	Requirements for initial commissioning						
	7.2	Determining the P ₀ minimum operating pressure for the controller 9						
	7.3	Filling th	e device with water	9				
	7.4	Paramet	rising the controller in the Customer menu	9				
	7.5	Functior	n test	9				
	7.6	Starting	Automatic mode	10				
8	Opera	ation		10				
	8.1	Operatir	ng modes	10				
		8.1.1	Automatic mode	10				
		8.1.2	Manual mode	10				
		8.1.3	Stop mode	10				
		8.1.4	Summer operation	10				
		8.1.5	Restarting	10				
9	Contr	oller		11				
	9.1	Operato	r panel	11				
	9.2	Configu	ring settings in the controller	11				
		9.2.1	Customer menu	12				
		9.2.2	Service menu	12				
	9.3	Message	12					
10	Maint	tenance		14				
	10.1	Mainten	ance schedule	14				
	10.2	Exterior	leak test	14				
	10.3	Cleaning) the dirt trap	14				
11	Disas	sembly.		14				
12	Anne	x		15				
	12.1	Reflex C	ustomer Service	15				
	12.2	Conform	nity and standards	15				
	12.3	Guarant	ee	15				

1 Notes on the operating manual

This operating manual is an important aid for ensuring the safe and reliable functioning of the device.

Reflex Winkelmann GmbH accepts no liability for any damage resulting from failure to observe the information in this operating manual. In addition to the requirements set out in this operating manual, national statutory regulations and provisions in the country of installation must also be complied with (concerning accident prevention, environment protection, safe and professional work practices, etc.).

This operating manual describes the device with basic equipment and interfaces for optional equipment with additional functions.



Notice!

Every person installing this equipment or performing any other work at the equipment is required to carefully read this operating manual prior to commencing work and to comply with its instructions. The manual is to be provided to the product operator and must be stored near the product for access at any time.

2 Liability and guarantee

The device has been built according to the state of the art and recognised safety rules. Nevertheless, its use can pose a risk to life and limb of personnel or third persons as well as cause damage to the system or other property.

It is not permitted to make any modifications at the device, such as to the hydraulic system or the circuitry.

The manufacturer shall not be liable nor shall any warranty be honoured if the cause of any claim results from one or more of the following causes:

- Improper use of the device.
- Unprofessional commissioning, operation, service, maintenance, repair or installation of the device.
- Failure to observe the safety information in this operating manual.
- Operation of the device with defective or improperly installed
- safety/protective equipment.
 Failure to perform maintenance and inspection work according to schedule.
- Use of unapproved spare parts or accessories.

Prerequisite for any warranty claims is the professional installation and commissioning of the device.



Arrange for Reflex Customer Service to carry out commissioning and annual maintenance, see chapter 12.1 "Reflex Customer Service" on page 15.

3 Safety

3.1 Explanation of symbols

3.1.1 Symbols and notes used

The following symbols and signal words are used in this operating manual.

Danger of death and/or serious damage to health

 The sign, in combination with the signal word 'Danger', indicates imminent danger; failure to observe the safety information will result in death or severe (irreversible) injuries.

Serious damage to health

 The sign, in combination with the signal word 'Warning', indicates imminent danger; failure to observe the safety information can result in death or severe (irreversible) injuries.

- Damage to health
- The sign, in combination with the signal word 'Caution', indicates danger; failure to observe the safety information can result in minor (reversible) injuries.

ATTENTION

Damage to property

 The sign, in combination with the signal word 'Attention', indicates a situation where damage to the product itself or objects within its vicinity can occur.



Note!

This symbol, in combination with the signal word 'Note', indicates useful tips and recommendations for efficient handling of the product.

3.2 Personnel requirements

Assembly, commissioning and maintenance as well as connection of the electrical components may only be carried out by knowledgeable and appropriately qualified electricians.

3.3 Personal protective equipment



Use the prescribed personal protective equipment as required (e.g. ear protection, eye protection, safety shoes, helmet, protective clothing, protective gloves) when working on the system.

Information on personal protective equipment requirements is set out in the relevant national regulations of the respective country of operation.

3.4 Intended use

The device is a pressurisation unit for heating and cooling water systems. It is intended to maintain the water pressure and to add water within a system circuit. Operation can only take place in system circuits with static pressurisation that are sealed against corrosion using the following water types:

- Non-corrosive
- Chemically non-aggressive
- Non-toxic

The ingress of atmospheric oxygen by permeation into the entire heating and cooling water system, make-up water and similar must be reliably minimized during operation.

3.5 Inadmissible operating conditions

The device is not suitable for the following applications:

- Mobile system operation.
- Outdoor operation.
- For use with mineral oils.
- For use with flammable media.
- For use with distilled water.



It is not permitted to make any modifications to the hydraulic system or the circuitry.

3.6 Residual risks

This device has been manufactured to the current state of the art. However, some residual risk cannot be excluded.



Risk of burns on hot surfaces

- Hot surfaces in heating systems can cause burns to the skin.
- Wear protective gloves.
- Please place appropriate warning signs in the vicinity of the device.

Risk of injury due to pressurised liquid

If installation, removal or maintenance work is not carried out correctly, there is a risk of burns and other injuries at the connection points, if pressurised hot water or hot steam suddenly escapes.

- Ensure proper installation, removal or maintenance work.
- Ensure that the system is de-pressurised before performing installation, removal or maintenance work at the connection points.



Risk of injury due to heavy weight

The devices are heavy. Consequently, there is a risk of physical injury and accidents.

Use suitable lifting equipment for transportation and installation.

Fillcontrol Auto Compact — 20.10.2020 - Rev. D



4 Description of the device

4.1 Description

The device is a makeup station for heating or cooling water systems with a pump and a system separator vessel. The device controller controls the freshwater makeup for the plant system.

You can select from two makeup variants for this device:

- Freshwater makeup for plant systems with a diaphragm expansion tank.
- Freshwater makeup for plant systems with a pressurisation station.

4.2 Overview



1	Control Basic controller
2	Position of the "LS" insufficient water switch in the mains separator tank
3	"BT" mains separator tank
4	"PIS" pressure transducer
5	Pump "PU"
0C	Overflow from the mains separator tank
WC	Fresh water make-up line to the device
DC	Make-up line to the system circuit

4.3 Identification

4.3.1 Nameplate

The nameplate provides information about the manufacturer, the year of manufacture, the manufacturing number and the technical data.



Information on the type plate	Meaning
Туре	Device name
Serial No.	Serial number
min. / max. allowable pressure P	Minimum/maximum permissible pressure
max. continuous operating temperature	Maximum temperature for continuous operation
min. / max. allowable temperature / flow temperature TS	Minimum / maximum permissible temperature / TS flow temperature
Year built	Year of manufacture
min. operating pressure set up on shop floor	Factory set minimum operating pressure
at site	Set minimum operating pressure
max. pressure saftey valve factory - aline	Factory set actuating pressure of the safety valve
at site	Set actuating pressure of the safety

4.3.2	Type code			
No.		Type code (exampl	e)	
1	Device designation			
2	Auto Compact	Fillcontrol Auto Compact	AC	8,5
3	Maximum working pressure (in bar)	1	2	3

4.4 Function



"FQIRA" contact water meter (optional accessory)
Fillsoft (optional accessory)
Fillcontrol Auto Compact
Pressure sensor
Fresh water make-up line to the device
Signal line for insufficient water switch
Make-up line to the system circuit
External signal line from a pressurisation unit

The device controller uses the pump to regulate the make-up with fresh water for the system circuit.

The controller monitors the following parameters:

- Make-up time
- Make-up cycles

• Make-up quantity, if an optional contact water meter is installed The controller will detect small leaks in the system. When a leak is detected, the controller interrupts the make-up with as soon as the make-up time or the makeup cycles are exceeded. An integrated insufficient water protection sensor deactivates the pump to prevent it from running dry.

You can select from two make-up variants for this device. These variants depend on the system circuit.

- Water make-up to system circuits with a diaphragm expansion vessel.
 The pressure transducer sends a signal to the controller if the pressure drops below the minimum working pressure of the system circuit. The controller activates the pump. The system circuit is replenished with fresh make-up water from the mains separator tank. For calculating the filling pressure in the system circuit, see chapter 7.2 "Determining the P₀ minimum operating pressure for the controller" on page 9.
- Water make-up using a pressurisation unit.
 - Pressurisation units are equipped with filling level monitors. When the filling level falls below the minimum level, the pressurisation unit sends a signal to the device controller. The controller activates the pump. The system circuit is replenished with fresh make-up water from the mains separator tank.

Note!

The make-up variant is set in the Customer menu, see chapter 9.2.1 "Customer menu" on page 12 .

4.5 Scope of delivery

The scope of delivery is described in the shipping document and the content is shown on the packaging.

- Proceed as follows:
- 1. Immediately after receipt of the goods, please check the shipment for completeness and damage.
- 2. Please notify us immediately of any transport damage.

Basic make-up equipment:

- The pre-wired device.
- Operating manual.

4.6 Optional equipment and accessories

The following optional equipment and expansion functions are available for this device:

- Fillset or Fillset Compact as add-on modules for drinking water systems.
- Softening with Reflex Fillsoft.
- Expansions for Reflex Basic controllers:
 - I/O modules
 - Bus modules:
 - Profibus DP
 - Ethernet



Separate operating instructions are supplied with accessories.

5 Technical data

Permissible ambient temperature	0 – 45 °C
Degree of protection	IP 54
Noise level	55 dB
Electric output	350 W
Power supply	230 V / 50 Hz
Fusing	4 A
Number of RS-485 interfaces	2
Weight	19.1 kg
Height	620 mm
Width	580 mm
Depth	290 mm
Inlet connection	G 1⁄2"
Outlet (return) connection	G ½"
Overflow connection	DN 32
Delivery rate	≤195 l/h
Max. supply pressure	6 bar
Max. delivery pressure	≤10 bar
Permissible gauge operating pressure	10 bar
Permissible operating temperature	30 °C
I/O module	Optional



6 Installation

Risk of serious injury or death due to electric shock.

- If live parts are touched, there is risk of life-threatening injuries.
- Ensure that the system is voltage-free before installing the device.
 Ensure that the system is secured and cannot be reactivated by other
- persons.
 Ensure that installation work for the electric connection of the device is carried out by an electrician, and in compliance with electrical engineering regulations.

Risk of injury due to pressurised liquid

If installation, removal or maintenance work is not carried out correctly, there is a risk of burns and other injuries at the connection points, if pressurised hot water or hot steam suddenly escapes.

- Ensure proper installation, removal or maintenance work.
- Ensure that the system is de-pressurised before performing installation, removal or maintenance work at the connection points.

Risk of burns on hot surfaces

Hot surfaces in heating systems can cause burns to the skin.

- Wear protective gloves.
- Please place appropriate warning signs in the vicinity of the device.

Risk of injury due to falls or bumps

Bruising from falls or bumps on system components during installation.
 Wear personal protective equipment (helmet, protective clothing, gloves, safety boots).



Confirm that installation and start-up have been carried out correctly using the installation and commissioning certificate. This action is a prerequisite for the making of warranty claims.

Have the Reflex Customer Service carry out commissioning and the annual maintenance.

6.1 Installation conditions

6.1.1 Incoming inspection

Prior to shipping, this device was carefully inspected and packed. Damages during transport cannot be excluded.

Proceed as follows:

- 1. Upon receipt of the goods, check the shipment for
 - completeness and
 - possible transport damage.
- 2. Document any damage.
- 3. Contact the forwarding agent to register your complaint.

6.2 Preparatory work

Preparing the device installation:

- Frost-free, well-ventilated room.
- Room temperature range: 0 °C to 45 °C.
 Filling connection.
 - If necessary, provide a DN 15 filling connection according to DIN 1988 T 4.
- Electric connection: 230 V~, 50 Hz, 16 A with upstream ELCB: Tripping current 0.03 A.

6.3 Execution

ATTENTION

Damage due to improper installation

Additional device stresses may arise due to the connection of pipes or system equipment.

- Ensure that pipes are connected from the device to the system without them being stressed or strained.
- If necessary, provide support structures for the pipes or equipment.

Note

Starting up of the pump causes vibration in the device. This transfers loud noises into the system pipes.

Connect the pipes to the device using flexible connections.

In systems with a diaphragm expansion tank, the device must be installed in the vicinity of the tank. To ensure that the required filling pressure for water make-up is recorded by the pressure transducer in the device. The filling pressure depends on the minimum operating pressure of the facility system. For calculating the minimum operating pressure, see chapter 7.2 "Determining the P_0 minimum operating pressure for the controller" on page 9.

Proceed as follows for the installation:

- 1. Position the device.
- 2. Create the water-side connections of the device to the system.
- Use connections with the same dimensions at the device for all lines.
 If required, create the interfaces according to the terminal plan.

6.3.1 Fitting the add-on components



6 — English

Fillcontrol Auto Compact — 20.10.2020 - Rev. D

One shut-off valve with dirt trap for the connection to the mains separator tank.

Install the following valves at the device:

One shut-off valve for the connection to the system circuit.

Proceed as follows:

- 1. Carefully remove the front cover from the device.
- 2. Remove the top cover from the device.
- 3. Install the shut-off valve with dirt trap and intermediate ring at the connection to the mains separator tank.
 - When tightening, ensure that the float valve in the mains separator tank is not twisted.
- 4. Check the vertical position of the float valve to prevent malfunction.
- 5. Install the shut-off valve at the connection of the pump to the system circuit.
- Extend the overflow from the mains separator tank.
 Terminate the extension in a drain.
- Place the top cover onto the housing.
- Install the from housing cover of the device.

The valves are installed.

6.3.2 Wall mounting

Mount the device at the wall. Bore holes for wall mounting are provided on the rear of the housing.



Select suitable fixing means according to the conditions below:

- Structure and condition of the wall.
- Device weight.



6.3.3 Hydraulic connection

6.3.3.1 Connection to the facility system

options for the connecting lines.

Note

Starting up of the pump causes vibration in the device. This transfers loud noises into the system pipes.

During installation, ensure the operability of the valves and the inlet

- Connect the pipes to the device using flexible connections.

Connection to the system



1	Contact water meter (optional accessory)
2	Reflex Fillsoft softening system (optional accessory)
3	Fillcontrol Auto Compact
WC	Make-up line to the device
DC	Make-up line to the system circuit
LIS	Filling level monitoring
	 External signal cable to the Levelcontrol make-up variant
LS	Insufficient water switch
PIS	Pressure sensor
	For the Magcontrol make-up variant

Prepare the connection as follows:

- 1. Select the "DN" nominal diameter for the make-up lines.
 - At a length of up to 10 metres: DN 15.
 - At a length beyond 10 metres: DN 20.

Flexibly connect the make-up lines.

- 2. Flexibly connect the "DC" make-up line to the pump's shut-off valve.
- 3. Connect the "DC" make-up line to the system circuit.
- Flexibly connect the "WC" make-up line to the shut-off valve of the mains separator tank.
- 5. Connect the "WC" make-up line to the external fresh water main.

The make-up lines are connected.

Note!

Use a pressure reducer in the "WC" make-up line if the mains water pressure exceeds 6 bar.

Note!

For selecting the make-up variants, see chapter 6.4 "Switching and make-up variants" on page 7.

6.4 Switching and make-up variants

"Magcontrol" pressure-dependent water make-up into the system circuit



ST	Dirt trap at the shut-off valve		PIS	Pressure sensor
	of the mains separator tank		DN	Nominal diameter of the make-up line
BT	Mains separator tank		LS	Insufficient water switch

Water make-up to system circuits with a diaphragm expansion vessel. The device must be installed in the vicinity of the diaphragm expansion vessel to ensure that the filling pressure for the fresh water make-up is recorded by the "PIS" pressure transducer in the device. For calculating the filling pressure, see chapter 7.2 "Determining the P₀ minimum operating pressure for the controller" on page 9.

"Levelcontrol" level-dependent water make-up into the system circuit.



LIS	Level sensor
	 To monitor the filling level in the pressurisation unit
WC	Make-up line to the device
ST	Dirt trap at the shut-off valve of the mains separator tank
BT	Mains separator tank
PU	Pump
PIS	Pressure sensor
LS	Insufficient water switch
DN	Nominal diameter of the make-up line

Water make-up to system circuits with a pressurisation unit.

Pressurisation units are equipped with filling level monitors. When the filling level falls below the minimum level, the pressurisation unit sends a signal to the device controller. The controller activates the pump. The system circuit is replenished with fresh make-up water.



Note!

For setting the make-up variants, see chapter 9.2.1 "Customer menu" on page 12 .

Note!

You may combine the device with softening systems (e.g. Reflex Fillsoft); available as optional accessories, see chapter 4.6 "Optional equipment and accessories" on page 5.

When using a Reflex Fillsoft, the PIS pressure transducer is installed downstream of the fitting and other installed components, such as a water meter. This prevents malfunctions when measuring the pressure. Remove the PIS pressure transducer from the device and fit it in the corresponding position in the system circuit. To do so, use a T-piece as a connector in the piping system.

6.5 Electrical connection

Risk of serious injury or death due to electric shock.

If live parts are touched, there is risk of life-threatening injuries.

- Ensure that the system is voltage-free before installing the device.
 Ensure that the system is secured and cannot be reactivated by other persons.
- Ensure that installation work for the electric connection of the device is carried out by an electrician, and in compliance with electrical engineering regulations.

Risk of serious injury or death due to electric shock

Some parts of the device's circuit board may still carry 230 V voltage even with the device physically isolated from the power supply.

- Before you remove the covers, completely isolate the device controller from the power supply.
- Verify that the main circuit board is voltage-free

Fillcontrol Auto Compact — 20.10.2020 - Rev. D

The following descriptions apply to standard systems and are limited to the necessary user-provided connections.

- Disconnect the system from the power source and secure it against unintentional reactivation.
- 2. Remove the cover

DANGER Risk of serious injury or death due to electric shock. Some parts of the device's circuit board may still be live with 230 V even after the device has been physically isolated from the power supply by pulling out of the mains plug. Before you remove the covers, completely isolate the device controller from the power supply. Verify that the main circuit board is voltage-free.

- 3. Install a screwed cable gland suitable for the respective cable. M16 or M20, for example.
- 4. Thread all cables to be connected through the cable gland.
- 5. Connect all cables as shown in the terminal diagram.
 - For installer supplied fusing, comply with the connected loads of the device , see chapter 5 "Technical data" on page 5.
- 6. Install the cover.
- 7. Connect the mains plug to the 230 V power supply.

8. Activate the system. The electrical connection is completed.

6.5.1 Terminal diagram



1	"L" fuse for electronics and solenoid valves
2	"N" fuse for solenoid valves
3	Solenoid valve (not for motor ball valve)
4	Group message
5	Not used
6	Not used
7	RS-485 interface
8	Shielding
9	Digital inputs
	Water meter
	Insufficient water
10	Power supply connection for a motor ball valve
11	Pressure analogue input
12	External make-up demand (only with "Levelcontrol")
13	Not used
14	Pump "PU"
15	Mains supply

Terminal number	Signal	Function	Wiring
1	PE		
2	Ν	230 V power supply via mains	Factory
3	L		
4	PE		
5	Ν	Pump for making-up.	Pre-wired
6	M 1		
13	СОМ		
14	NC	Group message (floating).	User, optiona
15	NO		

Terminal number	Signal	Function	Wiring	
16	Not assigned	External make-up request	User, optional	
17	Make-up (230 V)	From a pressurisation controller, for example		
18	Make-up (230 V)	(Set the controller to "Levelcontrol")		
22	PE (shield)	Pressure analogue input.		
23	- Pressure (signal)	For output to the display.For make-up actuation	Factory	
24	+ Pressure (+ 18 V)	For the "Magcontrol" make- up variant		
29	A			
30	В	RS-485 interface	User, optional	
31	GND			
32	+ 24 V (supply) E1	Supply for E1 and E2.	Pre-wired, bridged	
33	E1	Contact water meter (in "Fillset Impulse", for example) • Evaluation of the make-up. • Contact 32/33 closed = meter pulse.	User, optional	
34	E2	Connection for "LS" insufficient water switch • Prevents the pump from running dry.	Pre-wired, bridged	

6.5.2 RS-485 interface

The following options are available via the interface:

- Data polling by the controller.
 - Pressure
 - Pump operating states.
 - Cumulated quantity of the "FQIRA+" contact water meter.
 - All messages, see chapter 9.3 "Messages" on page 12.
- All entries in the fault memory.
- Communication with control centres. Communication with other equipment.
- Note!
 - If required, please request the RS-485 interface protocol from the Reflex Customer Service.
 - Connection details.
 - Accessory information and data.

6.5.2.1 Connecting the RS-485 interface

Connect the interface as follows:

- 1. For connecting the interface use only a cable with these properties: – LJYCY (TP), $4 \times 2 \times 0.8$, maximum overall bus length 1000 m.
- Use a shielded cable to connect the interface to terminals 29, 30, 31 of the main board in the control cabinet.
 - For connecting the interface, see chapter 6.5 "Electrical connection" on page 7.
- When using the device with a control centre not supporting an RS-485 interface (RS-232, for example), you must use a corresponding adapter.

6.6 Installation and commissioning certificate

Note!

The installation and commissioning certificate can be found at the end of the operating manual.

Commissioning

Note!

Confirm that installation and start-up have been carried out correctly using the installation and commissioning certificate. This action is a prerequisite for the making of warranty claims.

- Have the Reflex Customer Service carry out commissioning and the annual maintenance.

7.1 Requirements for initial commissioning

The device will be ready for initial commissioning when the tasks described in the "Installation" chapter have been completed. Note the following information on initial commissioning:

- The device is installed.
- The water connections to the system circuit are established.
- The device shut-off valves are closed.
 - Shut-off valve from the "DC" make-up line to the system circuit.
 Shut-off valve of the "WC" make-up line to the fresh water main.
 - "PIS" pressure monitoring is ready.
- The electrical connection has been created according to applicable national and local regulations.

Establish a 230 V power supply by plugging the power plug into a corresponding outlet. The controller is in Stop mode.

7.2 Determining the P_0 minimum operating pressure for the controller

The " P_0 " minimum working pressure for the device is used in system circuits with a diaphragm expansion vessel.

Calculate the "P₀" minimum working pressure for the device:



- The device is installed at the same level as the diaphragm expansion vessel:
 - hst = 0, P0 = p0*
- The device is installed at a lower level than the diaphragm expansion vessel:
 - $P_0 = p0 + h_{st}/10^*$
 - The device is installed at a higher level than the diaphragm expansion vessel:
 - P₀ = p0 h_{st}/10*

*p0 in bar, h_{st} in metres



Note!

Calculate the filling pressure for system circuit make-up using fresh water as follows:

Filling pressure $\ge P_0 + 0.3$ bar

Note!

When planning, note that the working range of the device must come within the pressurisation working range, which extends from the initial pressure "PA" to the final pressure "PE".

7.3 Filling the device with water

Risk of injury due to pump start-up

Hand injuries may occur when the pump starts up if you turn the pump motor at the impeller using a screwdriver.

Switch the pump to a zero-volts state before turning the pump at the fan wheel with a screwdriver.

ATTENTION

Device damage due to pump start-up

Pump damage may occur when the pump starts up if you turn the pump motor at the impeller using a screwdriver.

- Switch the pump to a zero-volts state before turning the pump at the
- fan wheel with a screwdriver.

main.

1.

3.

Fill water into the device:

separator tank.

- Check the proper closing of the float valve in the mains separator tank.
 Water must not flow from the device overflow.
 - Slowly open the shut-off valve in the "DC" make-up line to the system.
 The pressure line from the mains separator tank to the pump is filled with water from the mains separator tank.

Slowly open the shut-off valve in the "WC" make-up line from the mains

The mains separator tank is filled with water from the fresh water



Vent the pump (1):

- Remove the vent screw from the pump and vent the pump until bubblefree water escapes.
 - If necessary, manually turn the pump using a screwdriver at the fan wheel until bubble-free water escapes.
- 5. Tighten the vent screw and ensure that is does not leak.

The device is filled with water.

7.4 Parametrising the controller in the Customer menu

Use the Customer menu to display or correct system-specific values. In the course of commissioning, the factory settings must be adjusted for the systemspecific conditions.

- For adjusting the default settings, see chapter 9.2 "Configuring settings in the controller" on page 11.
- For information about controller operation, see chapter 9.1 "Operator panel" on page 11.

7.5 Function test

Perform a device function test. Check the following functions:

- Make-up with fresh water. Tightness of the float valve in the mains separator tank.
- Prior to the function test, provide the following prerequisites:
- Set the device controller to manual mode, see chapter 8.1.2 "Manual mode" on page 10.
- Clean the dirt trap, see chapter 10.3 "Cleaning the dirt trap" on page 14.

Proceed as follows:

Check the fresh water make-up function.

- 1. Remove the top ventilation cover from the device.
- 2. Remove the round cover of the mains separator tank.
- Activate the "PU" pump.
 Check the filling level of
 - Check the filling level of the mains separator tank.
 - If the filling level does not drop in the mains separator tank:
 - Shut down the pump.
 - Vent the pump.



5. Check the mechanical operation of the float valve rod (1).

- Press the rod downward.
- Fresh water will flow.
- Lift the rod.

The float valve is closed.

The fresh water make-up function is checked.

Test the float valve for leaks.

1. Shut down the pump.

- The ball valve in the make-up line is open.
- The ball valve downstream of the pump is open.
- 2. Ensure that the filling level in the mains separator tank does not change.
 - If the filling level rises to the overflow:
 - Remove the float valve.
 - Clean the seal.
 - Reinstall the float valve with the cleaned seal.

The float valve leak test has been completed.

Note!

For venting the pump, see Chapter Filling the device with water, Item 4, see chapter 7.3 "Filling the device with water" on page 9.



If necessary, contact the Reflex Customer Service, see chapter 12.1 "Reflex Customer Service" on page 15.

7.6 Starting Automatic mode

Automatic operation can be started after initial commissioning. The following prerequisites must be met for automatic operation:

- "P₀" minimum working pressure is entered in the controller.
- The device is filled with water.
- All required parameters are defined in the controller.
- The function test has been concluded.

Start the automatic mode at the operator panel of the controller:

- Press "Auto" for automatic operation.
 - The "Auto" LED at the operator panel illuminates to visually signal automatic operation.



The commissioning process is now concluded.

8 Operation

- 8.1 Operating modes
- 8.1.1 Automatic mode

Use:

After initial commissioning has been successfully completed

Start:

Press "Auto" on the controller. The Auto LED lights up.

Functions:

Automatic operation is suitable for continuous operation of the device. The controller monitors the make-up functions.

8.1.2 Manual mode

Use:

For testing and maintenance tasks.

Start:

Press "Manual" on the controller. The auto-LED on the controller operating panel and "PU" in the display flash as visual indicators of manual operation.

Functions:

After starting the manual mode, you can manually activate and deactivate the pump. Proceed as follows:

- Press "OK" on the controller's operating panel to activate the pump.
 The controller displays "PU !" as a visual signal of the pump being active.
- Press "OK" on the controller's operating panel to deactivate the pump.
 The controller displays "PU" as a visual signal of the pump being inactive.



The pump is automatically switched off after 10 seconds if it does not receive a make-up request.

8.1.3 Stop mode

Use:

For device commissioning

Start:

Press "Stop" on the controller. The Auto LED at the operator panel extinguishes.

Functions:

Except for the display of information, the device is non-functional in Stop mode. Function monitoring is stopped.

The "PU" pump is switched off.



The system returns an alarm if the Stop mode is activated for more than 4 hours.

If "Floating alarm contact?" in the Customer menu is set to "Yes", the system outputs the alarm to the group alarm contact.

8.1.4 Summer operation

The make-up with fresh water must be ensured even outside of the operation of the heating and cooling systems. Do not shut down the device when the pressure maintaining systems of the heating and cooling systems are in operation.

8.1.5 Restarting

Risk of injury due to pump start-up

Hand injuries may occur when the pump starts up if you turn the pump motor at the impeller using a screwdriver.

• Switch the pump to a zero-volts state before turning the pump at the fan wheel with a screwdriver.

ATTENTION

Device damage due to pump start-up

Pump damage may occur when the pump starts up if you turn the pump motor at the impeller using a screwdriver.

• Switch the pump to a zero-volts state before turning the pump at the fan wheel with a screwdriver.

After an extended standstill time (the device is de-energised or in Stop mode), the "PU" pump may jam.

Use a screwdriver to rotate the pump at the fan wheel of the pump motor before restarting.



A jamming of the "PU" pump is prevented during automatic operation thanks to forced starting action (after 24 hours).

9 Controller

9.1 Operator panel



1	Error LED		
	The Error LED illuminates in the event of a fault		
2	Display		
3	Auto LED		
	The Auto LED illuminates green in Automatic mode		
	The Auto LED flashes green in Manual mode		
	The Auto LED is not illuminated when the system is stopped		
4	ОК		
	Confirm actions		
5	Stop		
	For commissioning and entry of new values in the controller		
6	"Back" to the previous menu		
7	Manual		
	For tests and maintenance tasks		
8	Auto		
	For continuous operation		
9	"Forward" to the next menu		
10	Menu		
	Call up the Customer menu		
11	Quit		
	Acknowledge messages		
	·		

Selecting and changing parameters

- 1. Use "OK" (5) to select the parameter.
- 2. Use the "▼" (7) or "▲" (9) arrow keys to change the parameter.
- 3. Use "OK" (5) to confirm the parameter.
- 4. Use the "▼" (7) or "▲" (9) arrow keys to switch to a different menu option.
- 5. Use "Quit" (11) to switch to a different menu level.

9.2 Configuring settings in the controller

System-specific values can be corrected via the customer menu. In the course of initial commissioning, the factory settings must first be adjusted for the system-specific conditions.



For a description of the operation, see chapter 9.1 "Operator panel" on page 11 .

All grey marked menu items must be reviewed during commissioning.

Press "Manual" to switch to manual operation.

Press "Menu" to display the first main menu option "Customer menu".

To navigate and set the values:

- Use the "▼▲" arrow keys to navigate and set the values in the selected main menu.
- Press "OK" to open the next sub-menu.
- Press "OK" to confirm the changed setting in the sub-menu.

Indication on the display	Meaning		
Customer menu	Switch to the next main menu option.		
Language	Standard software in various languages.		
Time:	Adjust the "Hour", "Minute", and "Second" display when each begins to flash. This time is used for entries in the fault memory.		
Date:	Adjust the "Day", "Month", and "Year" display when each begins to flash. This date is used for entries in the fault memory.		
Fillcontrol / Magcontrol	 Select between the make-up variants "Levelcontrol" and "Magcontrol". "Magcontrol"In system circuits with a diaphragm expansion vessel "Levelcontrol" in system circuits with a pressurisation unit 		
Min.op.pressure 01.8 bar	The system displays the "Minimum working pressure" message when you have set the "Magcontrol" make-up variant. Enter the value for the minimum operating pressure. Notel Calculation of minimum operating pressure, see chapter 7.2 "Determining the P ₀ minimum operating pressure for the controller" on page 9		
Safety valve pressure	The system displays the "Safety valve pressure" message when you have set the "Magcontrol" make-up variant. Specify the tripping pressure of the applicable safety valve for the device protection. This is usually the safety valve at the system heat generator.		
Make-up	 Switch to the "Make-up" sub-menu. Press "OK" to open the menu. Use the "▼ ▲ " buttons to open the sub-menu. 		
Max. make-up time 010 min.	Pre-selected time for a make-up cycle. Upon expiry of this set time, the system interrupts the make-up and returns the "Make-up time" fault message.		
Max. make-up cycles 003 / 2 h	If the set number of make-up cycles is exceeded within two hours, the system interrupts the make-up and returns the "Make-up cycles" fault message.		
With water meter. JA	 YES: FQIRA+ contact water meter is installed, see chapter 4.6 "Optional equipment and accessories" on page 5. This is the prerequisite for the make-up volume monitoring and the operation of a softening system. NO: A contact water meter is not installed (standard model). 		
Make-up volume 000020 l	 Only displayed if "YES" has been set in the "With water meter" menu option. Press "OK" to delete the counter. Press "YES" to reset the value displayed to "0". Press "NO" to retain the displayed value. 		
Max. make-up volume 000100 l	 This value is only displayed if "YES" has been set in the "With water meter" menu option. When the set volume is exceeded, the system interrupts the make-up process and returns the error message "Max. make-up volume exceeded". 		
With softening JA	 This value is only displayed if "YES" has been set in the "With water meter" menu option. YES: Further queries follow about softening. NO: The system does not offer more queries regarding the softening process. 		

Fillcontrol Auto Compact — 20.10.2020 - Rev. D

Controller

Indication on the display	Meaning		
Disable make-up? JA	 This value is only displayed if "YES" has been set in the "With softening" menu option. YES: The system stops the make-up process when the set soft water capacity is exceeded. NO: The system does not stop the make-up process. The system displays the "Softening" message. 		
Hardness reduction 10 °dH	 This value is only displayed if "YES" has been set in the "With softening" menu option. Hardness reduction is calculated from the difference of the overall water hardness GH_{actual} and the target water hardness GH_{target}. Hardness reduction = GH_{actual}-GH_{target}I °dH Enter the value in the controller. Consult the manufacturer information for third-party products. 		
Cap. soft water 05000 I	 This value is only displayed if "YES" has been set in the "With softening" menu option. The attainable soft water capacity is calculated from the type of softening used and the specified hardness reduction. Fillsoft I, soft water capacity ≤ 6000/hardness red. I Fillsoft II, soft water capacity ≤ 12000/hardness red. I Enter the value in the controller. Consult the manufacturer information for the values of third-party products. 		
Remaining cap. soft w. 000020 l	This value is only displayed if "YES" has been set in the "With softening" menu option.Available soft water capacity.		
Replacement 18 months	 This value is only displayed if "YES" has been set in the "With softening" menu option. Manufacturer specification for the replacement interval of the softening cartridges, regardless of the calculated soft water capacity. The system displays the "Softening" message. 		
Next maintenance 012 months	 Recommended maintenance messages. Off: Without maintenance recommendation. 001 – 060: Maintenance recommendation in months. 		
Floating fault contact JA	 For the output of messages to the floating contact, see chapter 9.3 "Messages" on page 12. YES: Output of all messages. NO: Output of all messages identified with "xxx" ("01", for example). 		
Fault memory>	 Switch to the "Fault memory" sub-menu. Press "OK" to open the menu. Use the "▼▲" buttons to open the sub-menu. 		
ER 01xx	The last 20 alarms are stored with fault type, date, time, and fault code. See the chapter "Messages" for more information about the ER messages.		
Parameter memory>	 Switch to the "Parameter memory" sub-menu. Press "OK" to open the menu. Use the "▼▲" buttons to open the sub-menu. 		
P0 = xx.x bar Date Time	The last 10 entries of the minimum working pressure are stored with date and time.		
V0.60	Information about the software version		

9.2.1 Customer menu

The device controller is shipped with the following default settings. Use the Customer menu to adjust these values to local conditions. In special cases, it is possible to further adjust the values in the Service menu.

Parameter	Setting	Comment
Language	DE	Display language

12	_	Enalish	

Parameter	Setting	Comment
Fillcontrol XX	Magcontrol	For systems with diaphragm-type expansion vessel
Minimum operating pressure P ₀	1.5 bar	Only Magcontrol see chapter 7.2 "Determining the P ₀ minimum operating pressure for the controller" on page 9
Safety valve, pressure	3.0 bar	Tripping pressure for the safety valve at the heat generator in the system
Next maintenance	12 months	Time left to the next due maintenance
Volt-free contact	NO	Only the messages marked in the "Messages" list
Make-up		
Maximum make-up volume	1000 litres	Only if controller with "With water meter yes"
Maximum make-up time	20 minutes	Magcontrol
Maximum make-up cycles	3 cycles within 2 hours	Magcontrol
Softening (Only if "With softe	ening yes")	
Shut off make-up	NO	In the event of soft water residual capacity = 0
Hardness reduction	8°dH	= Setpoint – Actual
Maximum make-up volume	0 litres	Attainable make-up quantity
Soft water capacity	0 litres	Attainable water capacity
Cartridge replacement	18 months	Replace cartridge

9.2.2 Service menu

This menu is protected with a password. It can be accessed only by the Reflex Customer Service. A partial summary of the settings stored in the Service menu is proved in the Chapter Default settings.

Service menu

Parameter	Setting	Remarks	
Makeup			
Pressure differential, "NSP" makeup	0.2 bar	Only Magcontrol	
Pressure differential, filling pressure PF – P ₀	0.3 bar	Only Magcontrol	
Water quantity for each contact	10I/K	Only if a water meter is installed. (Fillset Impulse, for example)	
Maximum filling contacts	OFF	Limits the filling volume. Only if a water meter is installed. (Fillset Impulse, for example)	

9.3 Messages

The display provides alarms in plain text and the ER codes shown in the list. Use the arrow buttons to scroll through multiple alarms displayed at the same time. The fault memory stores the last 20 alarms for review, see chapter 7.4 "Parametrising the controller in the Customer menu" on page 9. Alarm causes can be eliminated by the operator or a specialist workshop. If this is

not possible, contact the Reflex Customer Service.



Clearing of the cause must be confirmed by pressing the "Ack" button on the operator panel. All other alarms are automatically reset as soon as the cause has been eliminated.



Floating contacts, setting in the Customer menu, see chapter 7.4 "Parametrising the controller in the Customer menu" on page 9.

ER Code	Alarm	Floating contact	Causes	Remedy	Alarm reset
01	Min. pressure – Only with Magcontrol	AL	 The set value for the "P₀" minimum working pressure has been exceeded. Water loss in the system. Expansion vessel defective. Fault at the "PU" pump. 	 Check the system for leaks. Replace the expansion vessel. Check the function in manual mode. "PU" pump 	"Quit"
02.1	Insufficient water		 No water in the mains separator tank. Ball valve in make-up line closed. Dirt trap clogged. Float valve defective. 	 Open the ball valve in the make-up line. Clean the dirt trap. Replace the float valve. 	
04.1	Pump	AL	 Pump does not start. "PU" pump is stuck. Pump motor defective. 10 A fuse defective. Contactor (Klixon) tripped. 	 Manually turn the pump to start. Replace the pump motor. Replace the fuse. Check the mechanical and electrical functions of the pump motor. 	"Quit"
06	Make-up time		 Set value for the make-up time has been exceeded. Severe water loss in the system. Make-up line not connected. Make-up rate insufficient. Make-up hysteresis too high. 	 Check the system for leaks. Connect the make-up system. Check the make-up rate. Check the make-up hysteresis. 	"Quit"
07	Make-up cycles		Set value for the make-up cycles has been exceeded. • Leakage in the system.	Check the system for leaks.	"Quit"
08	Pressure measurement – Only with Magcontrol	AL	 Controller receives incorrect signal. Pressure transducer plug not plugged in. Broken wire from "PIS" pressure transducer. "PIS" pressure transducer defective. 	 Plug in the plug. Replace the wire. Replace the "PIS" pressure transducer. 	"Quit"
10	Maximum pressure – Only with Magcontrol		 Set value for the maximum pressure has been exceeded. Safety valve defective. Pipe to system has insufficient diameter. 	 Check the actuating pressure of the safety valve. Replace the safety valve. Install new pipe to the system with sufficient diameter. 	"Quit"
11	Make-up volume – Only if "With water meter" is activated in the Customer menu.		 Set value of the water meter has been exceeded. Leakage in the system. Water volume per contact incorrectly set in the Service menu. 	Check the system for leaks.Check the set value.	"Quit"
16	Power failure		No power.	Check power supply.	-
19	Stop > 4 h		The device is in Stop mode for more than 4 hours.	Select Automatic mode.	-
20	Max. make-up volume		Set value for the make-up quantity has been exceeded.	Reset the "Make-up volume" meter in the Customer menu.	"Quit"
21	Maintenance recommended		Set value exceeded.	Carry out maintenance.	"Quit"
24	Softening		 Set value for the water capacity has been reached. Time interval for replacement of the softening cartridge has been reached. 	Replace the softening cartridge.	"Quit"
30	I/O module fault		 I/O module defective. Connection between option card and controller faulty. Option card defective. 	Inform Reflex Customer Service.	
31	EEPROM defective	JA	 EEPROM defective. Internal calculation error.	Inform Reflex Customer Service.	"Quit"
32	Undervoltage	JA	Supply voltage too low.	Check power supply.	
33	Adjustment parameter faulty		EEPROM parameter memory defective.	Inform Reflex Customer Service.	
34	Main board communication faulty		Connecting cable defective.Main board defective.	Inform Reflex Customer Service.	
35	Digital input voltage faulty		Short-circuit of input voltage.	Check the wiring at the digital inputs (water meter, for example).	
36	Analogue input voltage faulty		Short-circuit of input voltage.	Check the wiring at the analogue inputs (pressure/level).	

Fillcontrol Auto Compact — 20.10.2020 - Rev. D

reflex

English — 13

10 Maintenance

Risk of burns

Escaping hot medium can cause burns.

- Maintain a sufficient distance from the escaping medium.
- Wear suitable personal protective equipment (safety gloves and goggles).

Risk of serious injury or death due to electric shock.

If live parts are touched, there is risk of life-threatening injuries.

- Ensure that the system is voltage-free before installing the device.
 Ensure that the system is secured and cannot be reactivated by other persons.
- Ensure that installation work for the electric connection of the device is carried out by an electrician, and in compliance with electrical engineering regulations.

Risk of injury due to pressurised liquid

If installation, removal or maintenance work is not carried out correctly, there is a risk of burns and other injuries at the connection points, if pressurised hot water or hot steam suddenly escapes.

- Ensure proper installation, removal or maintenance work.
- Ensure that the system is de-pressurised before performing installation, removal or maintenance work at the connection points.

The device is to be maintained annually.

• The maintenance intervals depend on the local operational conditions.

The annual maintenance is displayed upon expiry of the set operating time. Use "Quit" to acknowledge the "Maintenance recommended" message. Reset the maintenance counter in the Customer menu.



Note!

Arrange for maintenance tasks must be carried out only by specialist personnel or Reflex Customer Service.

10.1 Maintenance schedule

The maintenance schedule is a summary of maintenance tasks to be carried out regularly.

Activity	Check	Wait	Clean	Interval
Check for leaks, see chapter 10.2 "Exterior leak test" on page 14 . • "PU" pump • Screw connections	x	x		Annually
Cleaning the dirt trap • see chapter 10.3 "Cleaning the dirt trap" on page 14.	x	x	x	Depending on the operating conditions
Check the make-up function see chapter 7.5 "Function test" on page 9 . 	x			Annually
Check the system-specific set values in the controller, see chapter 9.2.1 "Customer menu" on page 12 . • Minimum operating pressure "Po". • Safety valve pressure "Psv".	x			Annually

10.2 Exterior leak test

Check the following device components for leaks:

- "PU" pumps and screw fittings.
 - Seal any leaks at the connections or replace the connections, if required.
 - Seal leaking screw connections or replace, if required.

14 — English

10.3 Cleaning the dirt trap

Clean the "ST" dirt trap according to the following intervals:

- Commissioning.
- Long lasting operation.
- Depending on the operating conditions.
- Long lasting standstill.
- At the latest, after one year in continuous operation.



- 1. Press "Stop" on the controller's operator panel.
 - The device is non-functioning and the pumps are shut down.
- 2. Connect the ball valve upstream of the "ST" dirt trap in the make-up line to the mains separator tank.
- 3. Slowly unscrew the dirt trap insert (2) from the dirt trap (1) in order for the residual pressure to escape from the pipeline segment.
- 4. Pull the sieve from the dirt trap insert.
- 5. Rinse the sieve with clean water.
- 6. Use a soft brush to clean the sieve.
- 7. Reinsert the cleaned sieve into the dirt trap insert.
- 8. Check the seal of the dirt trap insert for damage.
- 9. Screw the dirt trap insert back into the housing of the "ST" dirt trap (1).
- 10. Open the ball valve upstream of the "ST" (1) dirt trap.
- 11. Switch to Automatic mode.

The dirt trap has been cleaned.



- Clean all other installed dirt traps in the system circuit (in the Fillset, for example).
 - Repeat the steps described above to clean the dirt trap.

11 Disassembly

Risk of serious injury or death due to electric shock.

If live parts are touched, there is risk of life-threatening injuries.

- Ensure that the system is voltage-free before installing the device.
- Ensure that the system is secured and cannot be reactivated by other persons.
- Ensure that installation work for the electric connection of the device is carried out by an electrician, and in compliance with electrical engineering regulations.

Risk of serious injury or death due to electric shock

Some parts of the device's circuit board may still carry 230 V voltage even with the device physically isolated from the power supply.

- Before you remove the covers, completely isolate the device controller from the power supply.
- Verify that the main circuit board is voltage-free.

Risk of burns

Escaping hot medium can cause burns.

- Maintain a sufficient distance from the escaping medium.
- Wear suitable personal protective equipment (safety gloves and goggles).

Risk of burns on hot surfaces

- Hot surfaces in heating systems can cause burns to the skin.
- Wait until hot surfaces have cooled down or wear protective safety gloves.
- The operating authority is required to place appropriate warning signs in the vicinity of the device.

Risk of injury due to pressurised liquid

If installation or maintenance work is not carried out correctly, there is a risk of burns and other injuries at the connection points, if pressurised hot water or steam suddenly escapes.

- Ensure proper disassembly.
- Ensure that the system is de-pressurised before performing the disassembly.

Proceed as follows:

- 1. Prior to dismantling, block off all "water"-side connections to the device.
- 2. Disconnect the system from the power supply and secure it against unintended reactivation.
- 3. Disconnect the power cable of the device from the power supply.
- Disconnect and remove all cables from the terminals of the device controller.
- Undo all hose and pipe connections between the device and the system and remove them completely.
- 6. Drain all water from the device.
- 7. If necessary, physically remove the device from the system.

The device is removed.

12 Annex

12.1 Reflex Customer Service

Central customer service

Central telephone number: +49 (0)2382 7069 - 0 Customer Service extension: +49 (0)2382 7069 - 9505 Fax: +49 (0)2382 7069 - 9523 E-mail: service@reflex.de

Technical Hotline

For questions about our products Telephone number: +49 (0)2382 7069-9546 Monday to Friday 8:00 to 16:30

12.2 Conformity and standards

Device conformity declarations are available on the Reflex homepage. www.reflex-winkelmann.com/konformitaetserklaerungen

Alternatively, scan the QR code:



12.3 Guarantee

The respective statutory guarantee regulations apply.

EN Installation and commissioning certificate - This device has been installed and commissioned in accordance with the instructions provided in the operating manual. The settings in the controller match the local conditions.



Тур / Туре:	
Po	
Psv	
Fabr. Nr. / Serial-No.	



9	Ser Contraction







Thinking solutions.

Reflex Winkelmann GmbH Gersteinstraße 19 59227 Ahlen, Germany

+49 (0)2382 7069-0



+49 (0)2382 7069-9546

www.reflex-winkelmann.com

